



JM PVC MEMBRANE ADHERED TO WALL WITH JM APPROVED MEMBRANE ADHESIVE (SEE NOTE 4)

FOAM ROD DIA. 1.5 TIMES LARGER THAN MAXIMUM GAP

JM PVC MEMBRANE ADHESIVE (FOR ADHERED SPECIFICATIONS ONLY)

JM PVC MEMBRANE ADHERED OR MECHANICALLY FASTENED

1 1/2" (38 mm) MIN. WELD (CONTINUOUS)

JM INSULATION/COVER BOARD

APPROVED DECK

JM APPROVED FASTENER AND PLATE 12" (304 mm) O.C. MAXIMUM PENETRATION DEPENDENT ON DECK MATERIAL(S). SEE SPECIFICATIONS FOR FURTHER INFORMATION

COMPRESSIBLE FILLER (MUST BE SUPPORTED)

2" (50 mm) MAXIMUM

NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
2. PLEASE SEE SINGLE PLY FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
4. JM APPROVED ADHESIVES OR USE ON VERTICAL FLASHING APPLICATIONS INCLUDED JM PVC MEMBRANE ADHESIVES (LOW VOC ONLY).
5. JM PVC EDGE SEALANT IS OPTIONAL ON CUT OR NON ENCAPSULATED EDGES OF PVC REINFORCED MEMBRANE. THIS INCLUDES FACTORY CUT MEMBRANE.

DRAWING NO.		<h1>EXPANSION JOINT (ROOF TO WALL)</h1>		 Johns Manville
<h2>P-EJ-01</h2>				
EXPANSION JOINT		MEMBRANE TYPE:	Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.	
		JM PVC		
SCALE	ISSUE DATE	MAXIMUM GUARANTEE TERM:		
N.T.S	08-07-19	30 YEAR		