



JM EPDM TAPE PRIMER
SEE NOTE 4

JM EPDM POURABLE
SEALER OR JM ONE PART
POURABLE SEALER

JM EPDM PEEL & STICK
POURABLE SEALER POCKET
ROLL BOTTOM FLANGE
ONTO MEMBRANE UNDER
PRESSURE WITH HAND
ROLLER

PENETRATION

APPROVED DECK

JM INSULATION / COVER BOARD

JM EPDM MEMBRANE

PLAN VIEW
FOR CUTTING
POCKET

JM EPDM TAPE
PRIMER-SEE NOTE 4

CUT POCKET AND BUTT
ENDS TOGETHER. COVER
CUT WITH JM 6" EPDM
PEEL & STICK FLASHING
AND RETURN DOWN INTO POCKET

JM EPDM PEEL &
STICK FLASHING
(RADIUS CORNERS)

NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP TO DATE INFORMATION.
2. PLEASE SEE SINGLE PLY FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
4. JM EPDM TAPE PRIMER OR JM SINGLE PLY MEMBRANE PRIMER (LOW VOC) MUST BE APPLIED ON ALL SURFACES COMING INTO CONTACT WITH JM EPDM PEEL & STICK FLASHINGS. ROLL MEMBRANE WITH HAND ROLLER UNDER PRESSURE AT SEAM.
5. ALL SEALANTS / CAULKING SHALL BE PERIODICALLY INSPECTED AND MAINTAINED BY THE BUILDING OWNER THROUGHOUT THE LIFE OF THE ROOF.
6. MAINTAIN 2" MIN. CLEARANCE FROM PENETRATION TO EDGE OF SEALER POCKET.
7. PRIME INSIDE OF SEALER POCKET WITH EPDM TAPE PRIMER OR JM SINGLE PLY MEMBRANE PRIMER (LOW VOC).
8. THIS DETAIL IS ALSO APPROVED FOR MULTIPLE PENETRATIONS PROVIDED THE 2" CLEARANCE IS MAINTAINED.

DRAWING NO. E-FP-06		EPDM POURABLE SEALER POCKET		 <p>Johns Manville</p>
REPLACES EP-6		MEMBRANE TYPE: JM EPDM	<p>Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.</p>	
SCALE N.T.S	ISSUE DATE 1-11-17	MAXIMUM GUARANTEE TERM: 20 YEAR		