



NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP TO DATE INFORMATION.
2. PLEASE SEE SINGLE PLY FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
4. JM EPDM MEMBRANE MUST BE CLEANED, THEN PRIMED ON TOP OF MEMBRANE AT PEEL & STICK FLASHING WITH JM EPDM TAPE PRIMER OR JM SINGLE PLY MEMBRANE PRIMER (LOW VOC). ROLL MEMBRANE WITH ROLLER UNDER PRESSURE AT PEEL & STICK FLASHING OVER EPDM MEMBRANE.
5. CUT PVC PIPE MINIMUM 2" (51 mm) HIGH AND OF SUFFICIENT WIDTH TO ALLOW 1" (25 mm) OF SPACE BETWEEN PENETRATIONS AND BETWEEN PVC SHELL AND PENETRATIONS. MEMBRANE MUST EXTEND TO WITHIN 1/2" (13 mm) OF PENETRATION.
6. ALL SEALANTS / CAULKING SHALL BE PERIODICALLY INSPECTED AND MAINTAINED BY THE BUILDING OWNER THROUGHOUT THE LIFE OF THE ROOF.

PENETRATION POCKET WITH PEEL & STICK FLASHING

DRAWING NO.
3E-FP-05
PENETRATION

MEMBRANE TYPE:
JM EPDM
MAXIMUM GUARANTEE TERM:
30 YEAR

ISSUE DATE
10-01-20
SCALE
N.T.S

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy for general educational purposes only. This complimentary assistance is not to be either used or relied upon by anyone as a substitute for professional engineering design and documentation required by any building code, contract, or applicable law. By accepting the general conceptual information, you agree it does not constitute any representations, endorsements of, or an assumption by Johns Manville of any duty or liability for either the adequacy of the design of a building, any of its components or the sufficiency of any construction.

