

Bulletin Number: T19-002

Date: March 14, 2019

Distribution: External

Johns Manville Peak Advantage® Guarantee Requirements for JM SECUROCK® Gypsum-Fiber Roof Board in Modified Asphalt and EPDM Systems

Johns Manville offers one of the most comprehensive system guarantees in the roofing industry. In order to sustain this valuable service to our customers and partner contractors, JM is changing the system requirements for Peak Advantage Guarantees which cover the following NDL assemblies.

To qualify for the guarantee, the roofing system must meet the following requirements:

- All adhered (cold applied, heat weldable, hot applied, self-adhered) modified APP and SBS cap and base sheets installed over fastened insulation and SECUROCK Gypsum-Fiber Roof Board must contain polyester reinforcement. No glass reinforcement is acceptable in mechanically attached insulation and SECUROCK Gypsum-Fiber assemblies.
- All adhered modified APP and SBS base sheets installed over fastened insulation with adhered SECUROCK Gypsum-Fiber must contain polyester reinforcement. Glass or polyester reinforced cap sheets are acceptable over the polyester reinforced base sheet with an adhered SECUROCK Gypsum-Fiber.
- All adhered modified APP and SBS cap and base sheets installed over adhered insulation and SECUROCK Gypsum-Fiber may contain glass or polyester reinforcement. Glass or polyester reinforced cap sheets are acceptable over adhered insulation and SECUROCK Gypsum-Fiber.
- JM SECUROCK Gypsum-Fiber board thickness must be 0.5" or greater when installing:
 - Adhered modified APP and SBS assemblies
 - EPDM adhered systems, reinforced and non-reinforced membranes of all thicknesses

Please visit www.jm.com/roofing to view the latest system requirements and installation guidelines or contact JM Guarantee Services at (800) 922-5922 option 3.

Eric Olson
Guarantee Services Manager