



THOROUGHLY CLEAN METAL DRIP EDGE AND APPLY JM PMMA METAL PRIMER PRIOR TO INSTALLATION OF JM PMMA MEMBRANE FLASHING

JM PMMA MEMBRANE FLASHING EXTENDS 4" (102 mm) MIN. ONTO PREPARED AND PRIMED FIELD MEMBRANE

ENSURE ALL MEMBRANE TERMINATIONS ARE ENCAPSULATED IN JM PMMA RESIN

RUN JM PMMA FLASHING OVER TOP OF PARAPET AND DOWN EXTERIOR FACE OF PARAPET

APPROPRIATE FASTENERS 6" O.C. STAGGERED 1"

METAL CLEAT GAUGE, FASTENER AND SPACING PER SMACNA, NRCA OR JM REQUIREMENTS. (MINIMUM 24 GAUGE, 6" (150 mm) O.C. MAX.)

PREPARE, LEVEL & PATCH SUBSTRATE WITH JM PMMA REPAIR PASTE AFTER PRIMING & PRIOR TO INSTALLATION OF JM PMMA MEMBRANE

ENSURE FULL RESIN SATURATION OF JM PMMA SCRIM AND CONTACT WITH SUBSTRATE

JM PMMA MEMBRANE FLASHING EXTENDED 4" MIN. HORIZONTALLY ONTO PREPARED AND PRIMED FIELD MEMBRANE

ENSURE ALL MEMBRANE TERMINATIONS ARE ENCAPSULATED IN JM PMMA RESIN

BITUMINOUS FIELD MEMBRANE

APPROVED WALL / CURB

APPROVED DECK

NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
2. PLEASE SEE JM PMMA FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
4. JM PMMA MEMBRANE FLASHING CONSISTS OF JM PMMA STANDARD RESIN, JM PMMA SCRIM, JM PMMA STANDARD RESIN. USE THE APPROPRIATE JM PMMA PRIMER DEPENDING ON TYPE OF SUBSTRATE.

| | | | | |
|-----------------|------------|--|--|--|
| DRAWING NO. | | TYPICAL PARAPET WALL FLASHING W/ INTEGRATED METAL DRIP EDGE | |  |
| LB-FW-03 | | | | |
| NEW DETAIL | | MEMBRANE TYPE: JM PMMA OVER BITUMINOUS | | <small>Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.</small> |
| SCALE | ISSUE DATE | MAXIMUM GUARANTEE TERM: | | |
| N.T.S | 6-18-18 | 20 YEAR | | |