

NOTES:

- 1. UPLIFT DESIGN SHOULD BE IN ACCORDANCE WITH ASCE-7.
- 2. SYSTEM COMPONENTS AND DESIGN MUST BE VERIFIED TO BE IN ACCORDANCE WITH THIS LAYOUT.
- 3. ASCE-7 DEFINES THE PERIMETER (X) AS THE LESSER OF 10% OF LEAST HORIZONTAL DIMENSION OR .4 x THE HEIGHT, BUT NOT LESS THAN 4% OF LEAST HORIZONTAL DIMENSION OR 3 FEET FOR BUILDINGS UNDER 60 FEET IN HEIGHT. OVER 60 FEET IN HEIGHT, ASCE-7 DEFINES THE PERIMETER (X) AS THE LESSER OF 10% OF LEAST HORIZONTAL DIMENSION ONLY.
- 4. THE CORNERS MAY BE TREATED AS PERIMETERS IF THE PARAPET IS GREATER THAN OR EQUAL TO 3 FEET ACCORDING TO ASCE-7.
- 5. ENSURE URETHANE ADHESIVE RIBBONS ARE APPLIED UNDER ALL AREAS OF THE FLEECE BACKED MEMBRANE WITH THE EXCEPTION OF THE 4" SALVAGE STRIP. URETHANE ADHESIVE ON THE MEMBRANE IN THE WELD AREAS WILL NEGATIVELY IMPACT THE BOND AND MUST BE REMOVED.

DRAWING NO. URETHANE ADHESIVE TPO FB TO INSULATION MEMBRANE TYPE: TPO FLEECE BACK MAXIMUM GUARANTEE TERM:

30 YEAR

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy for general educational purposes only. This complimentary assistance is not to be either used or relied upon by anyone as a substitute for professional engineering design and documentation required by any building code, contract, or applicable law. By accepting the general conceptual information, you agree it does not constitute any representations, endorsements of, or an assumption by Johns Manville of any duty or liability for either the adequacy of the design of a building, any of its components or the sufficiency of any construction.



SCALE N.T.S

ISSUE DATE 07-01-22