

JM EPDM MEMBRANE REINFORCED

JM EPDM MEMBRANE REINFORCED

CONTINUOUS BEAD OF JM SINGLE PLY CAULK IS REQUIRED AT CUT EDGES OF JM EPDM REINFORCED MEMBRANE-SEE NOTE 4

JM EPDM CUT EDGE (SEE NOTE 4)

NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
2. PLEASE SEE SINGLE PLY FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
4. JM SINGLE PLY LVOC CAULK IS REQUIRED ON CUT OR NON ENCAPSULATED EDGES OF EPDM REINFORCED MEMBRANE. THIS INCLUDES FACTORY CUT MEMBRANE.

REINFORCED EPDM MEMBRANE CUT EDGE LAP CAULK

DRAWING NO.

E-MS-01

MEMBRANE SEAMING

MEMBRANE TYPE:

JM EPDM

MAXIMUM GUARANTEE TERM:

N/A

ISSUE DATE

08-24-20

SCALE

N.T.S

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy for general educational purposes only. This complimentary assistance is not to be either used or relied upon by anyone as a substitute for professional engineering design and documentation required by any building code, contract, or applicable law. By accepting the general conceptual information, you agree it does not constitute any representations, endorsements of, or an assumption by Johns Manville of any duty or liability for either the adequacy of the design of a building, any of its components or the sufficiency of any construction.

